

INDUSTRIAL COMPONENT DATA

401725 LEGRAND COVER CUBREBORNAS BLIND

Brand: LEGRAND | Manufacturer Part Number: 401725



Manufacturer	LEGRAND
MPN / Reference	401725
Catalog number	401725
Category	Front plate (switchgear cabinet)
Minimum order	1 Pcs
Document ID	EO-DA8DE5A62D
Generated	2026-08-02

Product Overview

COVER CUBREBORNAS BLIND

Plain faceplate - for 2,3 or 4 rows Practibox³ cabinets

Practibox³ blank plate blind for boxes of 2 or more rows

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	LEGRAND > DIN MODULAR BOXES
--------------	-----------------------------

Additional Product Information

Pack (number of units)1

Volume (dm3)1.871

Weight (g)230.00

Product characteristicsAccessories

Plain faceplate for 18 modules per row cabinets

For 2, 3 or 4-rows cabinets

Allow fitting of non-modular equipments such as control and signalling units

General characteristicsFlush-mounting cabinets Practibox³ - from 8 to 72 modulesClass II

IP 40 - IK 07 with door

Self-extinguishing: resistance to incandescent wire 850 °C

Conform to IEC 60670-24 and IEC 62208 : allows to achieve assemblies conform to IEC 61439-3

ETIM for 401725 Cabinets and enclosures (EC000456)

Feature Name

Feature Value

Height (EF000040)

150 mm

Number of height units (EF003561)

1

Material (EF002169)

Plastic

Surface finishing (EF006569)

Other

Suitable for enclosure building width (EF000326)

493 mm

Width (EF000008)

370 mm

Suitable for enclosure building height (EF009583)

800 mm

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send LEGRAND / 401725 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.