

INDUSTRIAL COMPONENT DATA

404604 LEGRAND BAR C ALUMINUM 1250A

Brand: LEGRAND | Manufacturer Part Number: 404604



Manufacturer	LEGRAND
MPN / Reference	404604
Catalog number	404604
Category	Busbar
Minimum order	1 Pcs
Document ID	EO-58BB262FE6
Generated	2026-08-02

Product Overview

BAR C ALUMINUM 1250A

Bar aluminum VX3 IS - 1250 TO - height 1800 mm

VX³ IS aluminum bar - 1250A - H1800mm**STRUCTURED PRODUCT DATA**

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	LEGRAND > XL3 800-4000 ENERGY DISTRIBUTION CABINETS
--------------	---

Additional Product Information

Product features

Chassis column VX3 IS xx3 - Busbar aluminium copper tinned - special Profile for automatic connection through clips - Supports the bases VX3 IS for devices and dispatchers of row HX3 IS - Allows the distribution according to the IS basic, plus and premium in function of the bases and the delivery drivers are installed - Includes compartmentalization - Is mounted in a cabinet XL3 4000Barras aluminum tinned copper VX3 IS xx3 - previous Profile for automatic connection - back Profile in C for power - Equipped with profiles insulation IP 2X - Height 1800 mm - 1250 To General characteristics Spread IS a vertical VX3 IS up to 2000 - in closet XL3 4000

ETIM for 404604 Low-voltage industrial controls and switchgear (EC001522)

Feature Name

Feature Value

Model (EF000010)

Profile

Surface protection (EF000139)

Tinned

Length (EF001438)
1800 mm
Rated current In (EF008250)
1250 A
Flexible (EF000083)
No

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send LEGRAND / 404604 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.