

INDUSTRIAL COMPONENT DATA

405248 LEGRAND 10 CONNECTION MODULES L2

Brand: LEGRAND | Manufacturer Part Number: 405248



Manufacturer	LEGRAND
MPN / Reference	405248
Catalog number	405248
Category	Phase busbar
Minimum order	1 Pcs
Document ID	EO-79EBBE6BB8
Generated	2026-07-31

Product Overview

10 CONNECTION MODULES L2

Game connection module L2 dealer row 125A HX3

L2 connection demod set for row splitter 125A HX³
STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path **LEGRAND > XL3 800-4000 ENERGY DISTRIBUTION CABINETS**

Additional Product Information

Product features

Dealer of row 125 TO HX3 IS basic plug-in Modules - Allow the connection and the automatic disconnection of the modular apparatuses in the dealer row 125 - set of 10 plug-in modules L2 General characteristics

Distribution IS horizontal HX3 IS - up to 125 in cabinet XL3 4000

ETIM for 405248 Low-voltage industrial controls and switchgear (EC000215)

Feature Name

Feature Value

Suitable for devices with auxiliary switch (EF007217)

No

Suitable for devices with N-conductor (EF007218)

No

Number of phases (EF000351)

1

Width in number of modular spacings (EF002950)

1

Max. rated operation voltage Ue (EF007357)

400 V

Rated permanent current Iu (EF001389)

80 A

Type of electric connection (EF003961)

Fork

Suitable for number of devices (EF007241)

1

Number of poles (EF001391)

1

Colour (EF000007)

Grey

Insulated (EF000019)

Yes

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send LEGRAND / 405248 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.