

INDUSTRIAL COMPONENT DATA

75220111D LEGRAND 02B LBD 406 STRAIGHT ELEMENT 1.5M

Brand: LEGRAND | Manufacturer Part Number: 75220111D



Manufacturer	LEGRAND
MPN / Reference	75220111D
Catalog number	75220111D
Category	Busbar trunk unit
Minimum order	2 Pcs
Document ID	EO-38B67A79FF
Generated	2026-07-31

Product Overview

02B LBD 406 STRAIGHT ELEMENT 1.5M

Straight element for LBplus data LBD406 lighting management channel - 40A - 6 conductors / 1+1 sockets - 1.5m

LBplus data LBD406 channel straight element - 40A 6cond./1+1sockets 1.5m

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	LEGRAND
--------------	---------

Additional Product Information

Model Double

Current rating at 50 Hz AC 40 A

Number of poles 3

Number of conductors (without earthing) 6

Flexible No

Rated voltage at 50 Hz AC (Min-Max) 0-400 V

Number of Exit Points 2

Colour Grey

Protection Class (IP) IP55

Longitude 1500 mm

Width 35 mm

Height 46 mm

ETIM for 75220111D Power distribution systems (EC000091)

Feature Name
Feature Value
Height (EF000040)
46 mm
Model (EF000010)
Double
Degree of protection (IP) (EF005474)
IP55
Rated voltage AC 50 Hz (EF007065)
0 V
Number of tap-off units (EF007583)
2
Rated current AC 50 Hz (EF007684)
40 A
Flexible (EF000083)
No
Number of poles (EF001391)
3
Number of conductors (without earthing) (EF001148)
6
Colour (EF000007)
Grey
Length (EF001438)
1500 mm
Width (EF000008)
35 mm

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send LEGRAND / 75220111D with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.