

INDUSTRIAL COMPONENT DATA

75240102D LEGRAND 02B LBD406 ELEM REC 3M 4+4DER

Brand: LEGRAND | Manufacturer Part Number: 75240102D



Manufacturer	LEGRAND
MPN / Reference	75240102D
Catalog number	75240102D
Category	Busbar trunk unit
Minimum order	6 Pcs
Document ID	EO-3527C84B72
Generated	2026-08-02

Product Overview

02B LBD406 ELEM REC 3M 4+4DER

Straight element for LBplus data LBD632 lighting management channel - 63A - 2 conductors / 4+2 sockets - 3m
LBplus data LBD632 63A straight element 2 conductors/4+2 sockets 3m

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	LEGRAND
--------------	---------

Additional Product Information

Model Unique

Current rating at 50 Hz AC 63 A

Number of poles 1

Number of conductors (without earthing) 2

Flexible No

Rated voltage at 50 Hz AC (Min-Max) 0-400 V

Number of Exit Points 4

Colour Grey

Protection Class (IP) IP55

Longitude 3000 mm

Width 35 mm

Height 46 mm

ETIM for 75240102D Power distribution systems (EC000091)

Feature Name

Feature Value

Height (EF000040)

46 mm

Model (EF000010)

Single

Degree of protection (IP) (EF005474)

IP55

Rated voltage AC 50 Hz (EF007065)

0 V

Number of tap-off units (EF007583)

4

Rated current AC 50 Hz (EF007684)

63 A

Flexible (EF000083)

No

Number of poles (EF001391)

1

Number of conductors (without earthing) (EF001148)

2

Colour (EF000007)

Grey

Length (EF001438)

3000 mm

Width (EF000008)

35 mm

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send LEGRAND / 75240102D with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.