

INDUSTRIAL COMPONENT DATA

44207 MURRELEKTRONIK MMW ANALOG COUPLER COMPONENT

Brand: MURRELEKTRONIK | Manufacturer Part Number: 44207



Manufacturer	MURRELEKTRONIK
MPN / Reference	44207
Catalog number	44207
Category	Relays, converters, switches
Minimum order	1 unit
Document ID	EO-644ED53E2B
Generated	2026-07-29

Product Overview

44207 MURRELEKTRONIK MMW ANALOG COUPLER COMPONENT

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path MURRELEKTRONIK > Relays, converters, switches

Additional Product Information

INPUT: 0...5 V DC, 0...10 V DC, ± 10 V DC

INPUT: 0...20 mA, 4...20 mA

Screw terminals

Input, output, and supply voltage galvanically separated

General dataDimensions H×W×D 90×12.4×70 mm

Test isolation voltage 0.75 kV

Mounting method DIN-rail mountable (EN 60715)

Temperature range -25...+50 °C

DescriptionFunctional description Due to an integrated current limiter on the output, the output is short circuit and overload protected. A special characteristic of the MULTI Converter Art.-No. 6644207 includes: Analog voltage signals 0...5 V/0...10 V and -10...+10 V and current signals 0.

Voltage inputsInput voltage 0...5, 0...10, ± 10 V DCInput resistor approx. 100 k Ω

Current input signalsInput current 0...20 mA, 4...20 mA

Load approx. 75 Ω

Current outputsLoad max. 400 ?
Commercial datacountry of origin CZ
customs tariff number 85437090
EAN 4048879028479
eClass 27210990
Packaging unit 1

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send MURRELEKTRONIK / 44207 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.