

INDUSTRIAL COMPONENT DATA

2012758 OBO BETTERMANN PACKING GLAND 106/FL PG 16 8 19

Brand: OBO BETTERMANN | Manufacturer Part Number: 106 FL 16 8 19



Manufacturer	OBO BETTERMANN
MPN / Reference	106 FL 16 8 19
Catalog number	2012758
Category	Cable gland
Minimum order	50 Pcs
Document ID	EO-AB8E972400
Generated	2026-08-03

Product Overview

PACKING GLAND 106/FL PG 16 8 19

Flat cable threaded connection, PG thread Pg 16, stone grey. Flat-cable entry, choke-nipple design with PG connecting thread to DIN 40430, protection rating IP31, with pre-mounted support sealing ring 107/F.

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path **OBO BETTERMANN > VBS Connection and fastening systems - OBO BETTERMANN**

Additional Product Information

Bend protection no
 CO2 Footprint (GWP) Cradle-to-Gate 0,0451 kg CO2e / 1 Piece
 Colour Stone grey; RAL 7030
 Dimension PG16
 Dimension D 32,5 mm
 Dimension G PG16 mm
 Dimension L 42 mm
 Dimension L1 12 mm
 Dimension L2 30 mm
 Fibre-glass reinforced no
 Flat cable gland yes
 Flat cable/width, max. 19 mm
 Flat cable/width, min. 17 mm

Flat cables/thickness, max. 8 mm

Flat cables/thickness, min. 6 mm

For Ex zone Without

Impact-resistant no

Material Polyethylene

Protection rating IP31

Sealing insert, multiple no

Strain relief option no

Thread Pg 16

Thread type PG

Type of seal Sealing ring

Version for Straight

WAF 27

With locknut no

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send OBO BETTERMANN / 106 FL 16 8 19 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.