

INDUSTRIAL COMPONENT DATA

LCIS 650 3 FS 6209616 OBO BETTERMANN TRAY ESC PERF. SOLDD 60x500 FT

Brand: OBO BETTERMANN | Manufacturer Part Number: LCIS 650 3 FS



Manufacturer	OBO BETTERMANN
MPN / Reference	LCIS 650 3 FS
Catalog number	6209616
Category	Cable ladder/wide span cable ladder
Minimum order	3 m.
Document ID	EO-12097D6462
Generated	2026-07-31

Product Overview

TRAY ESC PERF. SOLDD 60x500 FT

LCIS 650 3 FS ladder tray, Perforated step, welded 60x500x3000 Steel, St, galvanized in band, DIN EN 10346

LCIS 60 ladder tray, 3 m C30 FS. Ladder tray with a wing height of 60 mm with welded C30 profile rungs, open upwards. Rolled sidebar as reinforcement and as edge protection. The fixing on the shoulder is carried out with LKS 40 fixing flanges. The groove measurement of the step is 16.5 mm; the suitable half-round clamp on profile is BS-H.... Magnetic insulation without cap 10 dB, with cap 15 dB.

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	OBO BETTERMANN > KTS cable support systems - OBO BETTERMANN
--------------	---

Additional Product Information

Cable ladder with 60 mm side height with welded C30 profile rungs which are open in an upwards direction. Rolled side rail for reinforcement and as edge protection. Fastening to the bracket takes place using clamps, type LKS 40. The slot dimension of the frame is 16.5 mm and the appropriate clamp clip is type 2056.

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send OBO BETTERMANN / LCIS 650 3 FS with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.