

INDUSTRIAL COMPONENT DATA

7205700 OBO BETTERMANN TERMINAL CERÁM. 04 DATA
FIREBOX T

Brand: OBO BETTERMANN | Manufacturer Part Number: TK 04



Manufacturer	OBO BETTERMANN
MPN / Reference	TK 04
Catalog number	7205700
Category	Single- and multi-pole terminal strip
Minimum order	5 Pcs
Document ID	EO-F29CB14F19
Generated	2026-08-01

Product Overview

TERMINAL CERÁM. 04 DATA FIREBOX T

Ceramic terminal. High-temperature-resistant ceramic terminal for refitting of the FireBox T series. Tested according to DIN EN 60998-2-1:2004.

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path OBO BETTERMANN > BSS fire protection systems - OBO BETTERMANN

Additional Product Information

Closing plate required no

CO2 Footprint (GWP) Cradle-to-Gate 0,0029 kg CO2e / 1 Piece

Colour Cream

Connectable conductor cross-section, single-wire, max. 4 mm²Connectable conductor cross-section, single-wire, min. 0,5 mm²

Connection position Side

Dimension 4 mm²

Explosion-tested version no

Height 21,5 mm

Insulation material Ceramic

Length 8,5 mm

Material Steatit

No. of terminals 2

Nominal cross-section, max. 4 mm²

Nominal cross-section, min. 0,5 mm²

Nominal current 32 A

Nominal voltage 400 V

Number of screwless terminals per pole 2

Permitted temperature range, max. 250 °C

Pole number 1

Transparent no

Version of electrical connection 1 Screw connection

Version of electrical connection 2 Screw connection

Width 21,5 mm

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send OBO BETTERMANN / TK 04 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.