

INDUSTRIAL COMPONENT DATA

7405086 OBO BETTERMANN UNIT P/MECAN BLIND GES R2B 7011

Brand: OBO BETTERMANN | Manufacturer Part Number: GES R2B 7011



Manufacturer	OBO BETTERMANN
MPN / Reference	GES R2B 7011
Catalog number	7405086
Category	Installation box for underfloor-installation
Minimum order	1 Pcs
Document ID	EO-45E1C6D959
Generated	2026-07-31

Product Overview

UNIT P/MECAN BLIND GES R2B 7011

Service outlet with blanking cover and opening contour, GES R2. Service outlet with blanking cover and opening contour for GES R2 floor socket for direct installation in the MT R2 installation socket. For use in dry-cleaned floors for indoor use.

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path OBO BETTERMANN > UFS Underfloor piping systems - OBO BETTERMANN

Additional Product Information

Approvals VDE

Cable outlet version No cable outlet

CO2 Footprint (GWP) Cradle-to-Gate 0,4501 kg CO2e / 1 Piece

Colour Iron grey; RAL 7011

Dimension 140x140x40

External diameter 140 mm

Floor care Dry

Floor covering protection frame yes

Material Polyamide

Opening mechanism Tool

Protection rating (IP) when unused IP40

Protection rating IK code IK10

Standard EN 50085-2-2

Suitable for cavity floor installation yes
Suitable for raised floor installation yes
Suitable for underfloor ducts no
Suitable for wet care no
Version for Round
Vertical load, small area to 500 N
With floor covering recess no

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send OBO BETTERMANN / GES R2B 7011 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.