

INDUSTRIAL COMPONENT DATA

ASL 733 25 G 1362768 OBO BETTERMANN Clamp with elongated hole 20-25mm electrozincated, DIN EN 12329 Steel, St

Brand: OBO BETTERMANN | Manufacturer Part Number: ASL 733 25 G



Manufacturer	OBO BETTERMANN
MPN / Reference	ASL 733 25 G
Catalog number	1362768
Category	Pipe saddle clamp
Minimum order	25 Pcs
Document ID	EO-1005035EA2
Generated	2026-08-06

Product Overview

Clamp with elongated hole 20-25mm electrozincated, DIN EN 12329 Steel, St
Clamp 733 G

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	OBO BETTERMANN > VBS Connection and fastening systems - OBO BETTERMANN
--------------	--

Additional Product Information

Clamp for mounting tubes and cables on the wall, ceiling and floor. With self-locking lid. Fixation through elongated hole. From clamp size 20 appropriate for mounting with nail guns and bolt guns.

Appropriate for function maintenance according to DIN 4102, part 12, function maintenance classes E 30 to E 90 (except ALU).

ETIM for 1362768 Cable and tube fixings (EC000127)

Feature Name

Feature Value

Diameter (EF004620)

20 mm

Number of cables/conduits (EF004421)

1

With distance to the wall (EF007571)

Yes

Model (EF000010)

Closed

Type of fastening (EF002442)

Screw hole

Material (EF002169)

Steel

Surface protection (EF000139)

Galvanic/electrolytic zinc plated

Halogen free (EF000025)

Yes

Suitable in fire resistance areas (EF007821)

Yes

Plastic sheathed (EF006600)

No

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send OBO BETTERMANN / ASL 733 25 G with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.