


INDUSTRIAL COMPONENT DATA

AZK 100 FT 6075258 OBO BETTERMANN AZ small duct perforated, 50x100x3000, Hot-dip galvanised, DIN EN ISO 1461..

Brand: OBO BETTERMANN | Manufacturer Part Number: AZK 100 FT



Manufacturer	OBO BETTERMANN
MPN / Reference	AZK 100 FT
Catalog number	6075258
Category	Cable tray/wide span cable tray
Minimum order	3 m.
Document ID	EO-E8F7E7B194
Generated	2026-07-31

Product Overview

AZ small duct perforated, 50x100x3000, Hot-dip galvanised, DIN EN ISO 1461, Steel, St

AZ small duct 100 FT. AZ channel with a side height of 50 mm.Magnetic shield insulation without cover 20 dB, with cover 50 dB.

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	OBO BETTERMANN > KTS cable support systems - OBO BETTERMANN > Accessories
--------------	---

Additional Product Information

CO2 Footprint (GWP) Cradle-to-Gate 4,4695 kg CO2e / 1 Meter

Colour zinc

Connector version Without connectors

Dimension 50x100x3000

Dimension 100 x 50 x 1,5

Height 50 mm

Length 3000 mm

Maintain electrical functions no

Material Steel

Mounting perforation in base yes

NATO hole pattern no

Plate thickness 1,5 mm
Rustproof steel, pickled no
Side perforation yes
Support spacing 1.0 m 1,7 kN/m
Support spacing 1.5 m 1,5 kN/m
Support spacing 2.0 m 1 kN/m
Support spacing 2.5 m 0,8 kN/m
Support spacing 3.0 m 0,25 kN/m
Surface Hot-dip galvanised
Usable cross-section 5000 mm²
Usable cross-section 50 cm²
Wide-span version no
Width 100 mm

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send OBO BETTERMANN / AZK 100 FT with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.