

INDUSTRIAL COMPONENT DATA

OKA-G20040240 7424020 OBO BETTERMANN Trunking unit, blank, height 40–240 mm

Brand: OBO BETTERMANN | Manufacturer Part Number: OKA-G20040240



Manufacturer	OBO BETTERMANN
MPN / Reference	OKA-G20040240
Catalog number	7424020
Category	Underfloor installation duct flush floor open
Minimum order	2 Pcs
Document ID	EO-BB8F0CDD76
Generated	2026-08-02

Product Overview

Trunking unit, blank, height 40–240 mm

OKA-G20040240 flush pavement channel, blind 2400x200x240 Steel, St, strip galvanized, DIN EN 10346

Channel unit, blind, height 40-240 mm

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	OBO BETTERMANN > UFS Underfloor piping systems - OBO BETTERMANN
--------------	---

Additional Product Information

With three blanking lids (L = 800 mm).

Type OKA-G20040240

Width mm 200

Length mm 2400

Trunking height mm 40-240

Covers pc. 3

Pack. m 2,4

Weight kg/100 m 867,080

ETIM for 7424020 Underfloor trunking and floor boxes (EC001901)

Feature Name

Feature Value

Width (EF000008)

200 mm

Length (EF001438)

2400 mm

Levelling range (EF005136)

40 mm

Mounting opening (EF005090)

None

Cover mounting opening (EF004340)

No

With partition panel (EF007973)

No

Bottom duct (EF004547)

No

Material side wall/bottom duct (EF005415)

Steel

Surface side wall/bottom duct (EF008008)

Galvanised

Decoupling possibility base from main body (EF007746)

Yes

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send OBO BETTERMANN / OKA-G20040240 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.