

INDUSTRIAL COMPONENT DATA

MB 1+NPE 5096650 OBO BETTERMANN MultiBase 1-pole + NPE,

Brand: OBO BETTERMANN | Manufacturer Part Number: MB 1+NPE



Manufacturer	OBO BETTERMANN
MPN / Reference	MB 1+NPE
Catalog number	5096650
Category	Basic element for surge protection device
Minimum order	1 Pcs
Document ID	EO-A899460184
Generated	2026-08-02

Product Overview

MultiBase 1-pole + NPE,
MultiBase base + NPE. • Suitable for V 25-B+C, V 20-C and V10-C• Pre-mounted and ready for connection• Multifunction terminals for easy connection to series-mounted devices• Upper parts can be rotated through 180 degrees• For TN-S and TT network systems

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path

OBO BETTERMANN > TBS Transient and lightning protection systems - OBO BETTERMANN > Surge , arrestor,

Additional Product Information

CO2 Footprint (GWP) Cradle-to-Gate 0,5975 kg CO2e / 1 Piece
Conductor cross-section, rigid (single-wire/multiwire), max. 35 mm²
Conductor cross-section, rigid (single-wire/multiwire), min. 2,5 mm²
Dimension 1+NPE
Installation type DIN rail 35 mm
Network form Other
Operating temperature, max. 80 °C
Operating temperature, min. -40 °C
Permitted temperature range, max. 80 °C
Permitted temperature range, min. -40 °C
Pole version 1+N/PE
Protection rating IP20

Remote signalling no
Version for 1+NPE

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send OBO BETTERMANN / MB 1+NPE with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.