

INDUSTRIAL COMPONENT DATA

MB 4+FS 5096682 OBO BETTERMANN MultiBase 2-pole with signal contact,

Brand: OBO BETTERMANN | Manufacturer Part Number: MB 4+FS



Manufacturer	OBO BETTERMANN
MPN / Reference	MB 4+FS
Catalog number	5096682
Category	Basic element for surge protection device
Minimum order	1 Pcs
Document ID	EO-E1EEEE7FE5B
Generated	2026-08-02

Product Overview

MultiBase 2-pole with signal contact,
Base, MultiBase with remote signalling. • Suitable for V 25-B+C, V 20-C and V10-C • Pre-mounted and ready for connection • Multifunction terminals for easy connection to series-mounted devices • Upper parts can be rotated through 180 degrees • With remote signalling, potential-free NO contact, for function monitoring

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path

OBO BETTERMANN > TBS Transient and lightning protection systems - OBO BETTERMANN > Surge , arrestor,

Additional Product Information

CO2 Footprint (GWP) Cradle-to-Gate 1,198 kg CO2e / 1 Piece
Conductor cross-section, rigid (single-wire/multiwire), max. 35 mm²
Conductor cross-section, rigid (single-wire/multiwire), min. 2,5 mm²
Dimension 4-polig+FS
Installation type DIN rail 35 mm
Network form Other
Operating temperature, max. 80 °C
Operating temperature, min. -40 °C
Permitted temperature range, max. 80 °C
Permitted temperature range, min. -40 °C
Pole version 4
Protection rating IP20

Remote signalling yes

Version for 4-pole

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send OBO BETTERMANN / MB 4+FS with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.