

INDUSTRIAL COMPONENT DATA

132 N-DK 5202566 OBO BETTERMANN Roof conductor holder for ridge tiles, Hot-dip galvanised, DIN EN ISO 1461, ..

Brand: OBO BETTERMANN | Manufacturer Part Number: 132 N-DK



Manufacturer	OBO BETTERMANN
MPN / Reference	132 N-DK
Catalog number	5202566
Category	Roof conductor holder for lightning protection
Minimum order	20 Pcs
Document ID	EO-A52C7650B8
Generated	2026-08-02

Product Overview

Roof conductor holder for ridge tiles, Hot-dip galvanised, DIN EN ISO 1461, Steel, St

Driver support. on roof 132 N-DK, for ridge tile 8mm Steel, St, Hot-dipped galvanized, DIN EN ISO 1461

Conductor support on roofs for ridge tile, 180-240 mm, Rd 8-10, FT. • Adjustable between 180 and 240 mm• With 3 M8 threaded bolts for positioning a rider mount

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path OBO BETTERMANN > TBS Transient and lightning protection systems - OBO BETTERMANN > Surge , external

Additional Product Information

- Adjustable from 180-240 mm
- With conductor 177/20, polyamide, grey
- With 3 M8 threaded nipples for positioning the holder

ETIM for 5202566 Earthing, lightning and surge protection (EC000507)

Feature Name

Feature Value

Mounting type conductor (EF004183)

With grip clamp

Conductor diameter (EF004211)

8 mm

Application (EF000041)

Ridge/hip

Mounting method (EF000003)

Stretchable

Chucking range (EF002391)

180 mm

Material of holder (EF004251)

Plastic

Material of carrier (EF004254)

Steel

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send OBO BETTERMANN / 132 N-DK with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.