


INDUSTRIAL COMPONENT DATA

250 AS-FT 5313031 OBO BETTERMANN Diagonal clamp , Hot-dip galvanised, DIN EN ISO 1461, Steel, St

Brand: OBO BETTERMANN | Manufacturer Part Number: 250 AS-FT



Manufacturer	OBO BETTERMANN
MPN / Reference	250 AS-FT
Catalog number	5313031
Category	Connector for lightning protection
Minimum order	25 Pcs
Document ID	EO-31B8DC0B0D
Generated	2026-08-02

Product Overview

Diagonal clamp , Hot-dip galvanised, DIN EN ISO 1461, Steel, St

Diagonal clamp for flat conductors and round conductors FT. • For reinforced steels Ø 6-22 mm and flat conductors 50 x 4• Mounted with bolts M10 x 40• Version ...-AS with bolts M10 x 30• Simple mounting through open slot

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path

OBO BETTERMANN > TBS Transient and lightning protection systems - OBO BETTERMANN > Surge , external

Additional Product Information

CO2 Footprint (GWP) Cradle-to-Gate 0,6583 kg CO2e / 1 Piece

Dimension 88x30x45

Dimension A 30 mm

Dimension B 88 mm

Dimension L 20 mm

Fit Rd 6-22/ max. FL50 mm

Flat conductor width, conductor 2, max. 50

Intermediate plate no

Lightning current carrying capacity H/100 kA

Material Steel

Round conductor diameter, conductor 1, max. 22 mm

Round conductor diameter, conductor 1, min. 6 mm

Short-circuit current (50 HZ)(1 s; <=300°C) 7,3 kA

Suitable for connection Miscellaneous

Surface Hot-dip galvanised

Type of connector Connectors

Type of fastening screw Hexagonal bolt

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send OBO BETTERMANN / 250 AS-FT with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.