


INDUSTRIAL COMPONENT DATA

259 A FT 5315514 OBO BETTERMANN Parallel clamp , Hot-dip galvanised, DIN EN ISO 1461, Steel, St

Brand: OBO BETTERMANN | Manufacturer Part Number: 259 A FT



Manufacturer	OBO BETTERMANN
MPN / Reference	259 A FT
Catalog number	5315514
Category	Connector for lightning protection
Minimum order	25 Pcs
Document ID	EO-60B7466342
Generated	2026-08-01

Product Overview

Parallel clamp , Hot-dip galvanised, DIN EN ISO 1461, Steel, St

Parallel terminal block 259 A FT, 10-20mm Steel, St, Hot-dip galvanized, DIN EN ISO 1461

Parallel clamp for the connecting of reinforcing steels FT. • For connecting reinforced steels Ø 10–20 mm• Mounted with M10 x 40 bolts

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path

OBO BETTERMANN > TBS Transient and lightning protection systems - OBO BETTERMANN > Surge , external

Additional Product Information

CO2 Footprint (GWP) Cradle-to-Gate 0,4447 kg CO2e / 1 Piece

Dimension 10-20mm

Dimension A 35 mm

Dimension B 62 mm

Fit Ø 10-20 mm

Intermediate plate no

Lightning current carrying capacity H/100 kA

Material Steel

Suitable for connection Miscellaneous

Surface Hot-dip galvanised

Type of connector Parallel connector

Type of fastening screw Hexagonal bolt

ETIM for 5315514 Earthing, lightning and surge protection (EC000514)

Feature Name

Feature Value

Material (EF002169)

Steel

Surface protection (EF000139)

Hot dip galvanized

Type of fastening screws (EF000609)

Hexagon screw

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send OBO BETTERMANN / 259 A FT with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.