

INDUSTRIAL COMPONENT DATA

RD 8-ALU-T 5021294 OBO BETTERMANN Round conductors tordier quality, 8mm, Aluminium, Alu

Brand: OBO BETTERMANN | Manufacturer Part Number: RD 8-ALU-T



Manufacturer	OBO BETTERMANN
MPN / Reference	RD 8-ALU-T
Catalog number	5021294
Category	Round conductor/wire for lightning protection
Minimum order	150 Pcs
Document ID	EO-F82E1DF4F7
Generated	2026-08-01

Product Overview

Round conductors tordier quality, 8mm, Aluminium, Alu

Round conductor, aluminium. • Can be used as a conductor according to DIN EN 62561-2 (VDE 0185-561-2)• Corresponds to the requirements of VDE 0185-305 (IEC 62305)• RD 8 ALU: Semi-hard (E-ALMgSi0.5 corresponds to DIN 48801)• RD 8 ALU-T: Can be subjected to torsion (E-ALMgSi0.5 corresponds to DIN 48801)• RD 10 ALU: Pure aluminium (E-Al corresponds to DIN 48801)• AL and ALMgSi may not be routed directly on, in or under plaster, mortar or concrete, nor routed in the earth

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path **OBO BETTERMANN > TBS Transient and lightning protection systems - OBO BETTERMANN > Surge , external**

Additional Product Information

Cross-section 50 mm²

Diameter 8 mm

Dimension 8mm

Dimension D 8 mm

High voltage-resistant, insulated version no

Length tolerance ± 5 %

Material Aluminium

Material jacket Without

Material property Soft

Nomal ring (approx. m) 150

Normal ring (ca. kg) 20

Number of individual wires 1

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send OBO BETTERMANN / RD 8-ALU-T with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.