

INDUSTRIAL COMPONENT DATA

OKA D 500 4 7425064 OBO BETTERMANN Mounting lid for service unit GES22, 400x500x4, Strip-galvanised, DIN EN ..

Brand: OBO BETTERMANN | Manufacturer Part Number: OKA D 500 4



Manufacturer	OBO BETTERMANN
MPN / Reference	OKA D 500 4
Catalog number	7425064
Category	Cover for underfloor installation duct flush floor open
Minimum order	1 Pcs
Document ID	EO-1324BD4BF0
Generated	2026-07-27

Product Overview

Mounting lid for service unit GES22, 400x500x4, Strip-galvanised, DIN EN 10147, Steel, St
 Mounting cover, for portam set. GES4, 400x500x4, galvanised steel strip, DIN EN 10346
 Mounting lid for GES4, 400 mm. With mounting opening for the installation of an installation unit of nominal size 4. Mounting opening closed with blanking lid plate. Lid fixing screws contained in scope of delivery.

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	OBO BETTERMANN > UFS Underfloor piping systems - OBO BETTERMANN > Other
--------------	---

Additional Product Information

CO2 Footprint (GWP) Cradle-to-Gate 20,4079 kg CO2e / 1 Piece
 Cover fastening, locking no
 Dimension 400x500x4
 Dimension A 477 mm
 Dimension a 201 mm
 Dimension c 141 mm
 Length 400 mm
 Material Steel
 Material thickness 4 mm
 Mounting opening For service outlet
 Mounting opening Square
 Mounting opening cover yes

Number of mounting openings 1

Surface Strip galvanized

Width 500 mm

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send OBO BETTERMANN / OKA D 500 4 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.