

INDUSTRIAL COMPONENT DATA

OKA D 500 9 7425102 OBO BETTERMANN Mounting lid for service unit GES9, 400x500x4, Strip-galvanised, DIN EN 1..

Brand: OBO BETTERMANN | Manufacturer Part Number: OKA D 500 9



Manufacturer	OBO BETTERMANN
MPN / Reference	OKA D 500 9
Catalog number	7425102
Category	Cover for underfloor installation duct flush floor open
Minimum order	1 Pcs
Document ID	EO-F9C18074B6
Generated	2026-07-29

Product Overview

Mounting lid for service unit GES9, 400x500x4, Strip-galvanised, DIN EN 10147, Steel, St
Mounting cover, for portam set. GES9, 400x500x4, strip galvanised steel, DIN EN 10346
Mounting cap for GES9, 400 mm

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	OBO BETTERMANN > UFS Underfloor piping systems - OBO BETTERMANN > Other
--------------	---

Additional Product Information

With mounting opening for the installation of an installation unit of nominal size 9. Mounting opening closed with blanking lid plate. Lid fixing screws contained in scope of delivery.

ETIM for 7425102 Underfloor trunking and floor boxes (EC000894)

Feature Name

Feature Value

Width (EF000008)

500 mm

Length (EF001438)

400 mm

Material thickness (EF000386)

4 mm

Cover mounting opening (EF004340)

Yes

Material (EF002169)

Steel

Surface protection (EF000139)

Galvanised

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send OBO BETTERMANN / OKA D 500 9 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.