

INDUSTRIAL COMPONENT DATA

2056N 12 FT 1163124 OBO BETTERMANN Clamp clip , 8-12mm, Hot-dip galvanised, DIN EN ISO 1461, Steel, St

Brand: OBO BETTERMANN | Manufacturer Part Number: 2056N 12 FT



Manufacturer	OBO BETTERMANN
MPN / Reference	2056N 12 FT
Catalog number	1163124
Category	One-piece strut clamp
Minimum order	100 Pcs
Document ID	EO-3F71F6BC78
Generated	2026-07-27

Product Overview

Clamp clip , 8-12mm, Hot-dip galvanised, DIN EN ISO 1461, Steel, St

Clamp on profile 2056N 12 FT, 8-12mm Steel, St, Hot dipped galvanized, DIN EN ISO 1461

Clamp on profile, single FT plastic half-cane. Valid for all C-profiles with 11-12 mm groove width, at least 6.5 mm free inner height and at least 18.5 mm free inner width. Hot-dip galvanized steel clamp and screw. Polypropylene pressure clip, light gray RAL 7035, halogen-free. On request, the version with weld nut and/or lock nut is available for use in difficult conditions or with a risk of vibrations.

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	OBO BETTERMANN > VBS Connection and fastening systems - OBO BETTERMANN > Clamps BSS
--------------	---

Additional Product Information

Suitable for all C profile rails with slot width 11-12 mm; at least 6.5 mm clear internal height and at least 18.5 mm clear internal width.

Clip and bolt made of hot-dip galvanised steel.

Polypropylene pressure trough, halogen-free, colour light grey RAL 7035.

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send OBO BETTERMANN / 2056N 12 FT with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.