

INDUSTRIAL COMPONENT DATA

604 16 G 1003178 OBO BETTERMANN Attaching clip single lobe, 16mm, Electrogalvanised, DIN 50961, Steel, St

Brand: OBO BETTERMANN | Manufacturer Part Number: 604 16 G



Manufacturer	OBO BETTERMANN
MPN / Reference	604 16 G
Catalog number	1003178
Category	Pipe saddle clamp
Minimum order	100 Pcs
Document ID	EO-E5B716A4A8
Generated	2026-08-03

Product Overview

Attaching clip single lobe, 16mm, Electrogalvanised, DIN 50961, Steel, St

Fastening clip 604, light duty. Single-lobe fastening clip for cables and pipes.* Sizes 3 and 4 are not suitable for nail device*
Sizes 3 to 21 are not suitable for bolt-firing tool

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path

OBO BETTERMANN > VBS Connection and fastening systems - OBO BETTERMANN > Pizza metal fixation

Additional Product Information

CO2 Footprint (GWP) Cradle-to-Gate 0,0102 kg CO2e / 1 Piece

Dimension 16mm

Dimension A 6,5 mm

Dimension b 10 mm

Dimension D 16 mm

Dimension d 4,5 mm

Dimension e 6 mm

Dimension H 14,5 mm

Dimension L 31 mm

Dimension t 1 mm

Distance to the wall no

Fastening type Screw hole

For diameter 16

Halogen-free yes
Height 14,5 mm
Hole size 4,5 x 6 mm
Length 31 mm
Material Steel
Material thickness 1 mm
Nominal diameter 16 mm
Number of cables/pipes 1
Plastic-covered no
Suitable in fire protection area no
Surface Electrogalvanized
UV-resistant yes
Version for Single-lobe
Width 10 mm

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send OBO BETTERMANN / 604 16 G with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.