

INDUSTRIAL COMPONENT DATA

604 32 G 1003321 OBO BETTERMANN Attaching clip single lobe, 32mm, Electrogalvanised, DIN 50961, Steel, St

Brand: OBO BETTERMANN | Manufacturer Part Number: 604 32 G



Manufacturer	OBO BETTERMANN
MPN / Reference	604 32 G
Catalog number	1003321
Category	Pipe saddle clamp
Minimum order	100 Pcs
Document ID	EO-56D366954A
Generated	2026-08-03

Product Overview

Attaching clip single lobe, 32mm, Electrogalvanised, DIN 50961, Steel, St

Fastening clip 604, light duty. Single-lobe fastening clip for cables and pipes.* Sizes 3 and 4 are not suitable for nail device*
Sizes 3 to 21 are not suitable for bolt-firing tool

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path **OBO BETTERMANN > VBS Connection and fastening systems - OBO BETTERMANN > Pizza metal fixation**

Additional Product Information

CO2 Footprint (GWP) Cradle-to-Gate 0,0288 kg CO2e / 1 Piece

Dimension 32mm

Dimension A 8 mm

Dimension b 15 mm

Dimension d 5,5 mm

Dimension D 32 mm

Dimension e 7 mm

Dimension H 30 mm

Dimension L 49 mm

Dimension t 1,5 mm

Distance to the wall no

Fastening type Screw hole

For diameter 32

Halogen-free yes
Height 30 mm
Hole size 5,5 x 7 mm
Length 48,82 mm
Material Steel
Material thickness 1,5 mm
Nominal diameter 32 mm
Number of cables/pipes 1
Plastic-covered no
Suitable in fire protection area no
Surface Electrogalvanized
UV-resistant yes
Version for Single-lobe
Width 15 mm

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send OBO BETTERMANN / 604 32 G with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.