INDUSTRIAL COMPONENT DATA

# US-WMT (10X4) VT CUS 0829961 PHOENIX CONTACT Cable marker

**Brand: PHOENIX CONTACT | Manufacturer Part Number: US-WMT (10X4) VT CUS**



| | |
|---|---|
| Manufacturer | PHOENIX CONTACT |
| MPN / Reference | US-WMT (10X4) VT CUS |
| Catalog number | 0829961 |
| Category | Cable coding system |
| Minimum order | 1 Pcs |
| Document ID | EO-5AFBEDB419 |
| Generated | 2026-11-18 |

## Product Overview

Cable marker
Cable marker, available: per card, purple, labelled according to customer specifications, mounting class: introduce, cable diameter range: 0.6 ... 7 mm, usable area: 10x4mm, Number of individual indexes: 112

STRUCTURED PRODUCT DATA

## Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

## Classification & Catalog Path

| | |
|---|---|
| Catalog path | PHOENIX CONTACT > CABINET add-on |

## Additional Product Information

Key Commercial Data
Orderkey 0829961
Packing unit 1 pc
Note Made to Order (non-returnable)
Catalog page Page 187 (C-5-2013)
GTIN 4046356612852
Weight per Piece (excluding packing) 12.310 g
Custom tariff number 49119900
Country of origin DE (Germany)
Dimensions
Length (b) 4.3 mm
Width (a) 10 mm
Cable diameter 0.6 mm ... 7 mm

Ambient conditions
Ambient temperature (operation) -30 °C ... 80 °C
Recommended storage conditions 10-30 °C / 40-70 % relative humidity. Storage in the original packaging is recommended prior to processing.
General
Color violet
Components Silicone-free
Flammability rating according to UL 94 V0
Material PVC
Wipe resistance DIN EN 61010-1 (VDE 0411-1)
Number of individual labels 112
Number of individual labels per row 14
Printability Thermal transfer
Device 5146464 THERMOMARK CARD
Ink ribbon 5146451 THERMOMARK CARD-US-MAG1
0801371 THERMOMARK-RIBBON 110-TC
Test for substances that would hinder coating with paint or varnish VW PV 3.10.7:2005-02
Result Test passed
Test specification weathering-resistance Following ISO 4892-2:2013-03
Test duration 96 h
Wipe resistance test result Test passed
Salt spray test specification DIN EN 60068-2-11:2000-02
Test duration 96 h
Salt spray testing result Test passed
Alternating condensation climate with SO2 test specification following DIN 50018:2013-05
Climate level AHT 1.0 S
Cycles 2
Condensation test result Test passed
Wipe resistance of test specification inscriptions DIN EN 61010-1 (VDE 0411-1):2011-07
Result Test passe...

## REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / US-WMT (10X4) VT CUS with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.



Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.