INDUSTRIAL COMPONENT DATA

KMK HP (60X15) 0830722 PHOENIX CONTACT Cable marker carrier

Brand: PHOENIX CONTACT | Manufacturer Part Number: KMK HP (60X15)



Manufacturer	PHOENIX CONTACT
MPN / Reference	KMK HP (60X15)
Catalog number	0830722
Category	Mounting for labelling material
Minimum order	50 Pcs
Document ID	EO-440773155A
Generated	2026-11-19

Product Overview

Cable marker carrier
Cable marker bracket, transparent, unlabeled, mounting class: Mounting with cable ties, cable diameter: >= 9 mm, usable surface: 60 x 15 mm
Cable marker carrier, transparent, unlabeled, mounting type: Assembly with cable ties, cable diameter: >= 9 mm, text field height: 15 mm, text field width: 60 mm

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	PHOENIX CONTACT > MS Material

Additional Product Information

Technical dataProduct propertiesProduct type Marker carrier cable
Area of application Railway industry
Type Mounting set
Data management status
Article revision 01
DimensionsWidth 15 mm
Text field width 60.00 mm
Height 60 mm
Text field height 15.00 mm
Length 60 mm
External dimensions

Outside diameter 9 mm ... 50 mm
Material specificationsColor transparent
Material PC
Flammability rating according to UL 94 V0
Fire protection for rail vehicles (DIN EN 45545-2) R22 HL 1 - HL 3
Fire protection for rail vehicles (DIN EN 45545-2) R23 HL 1 - HL 3
Fire protection for rail vehicles (DIN EN 45545-2) R24 HL 1 - HL 3
Components halogen-free
Cable/lineExternal cable diameter >= 9.00 mm
Environmental and real-life conditionsTest for substances that would hinder coating with paint or varnish
Result Test passed
UV resistance
Specification ISO 4892-2:2013-03
Result Test passed
Test duration 96 h
Temperature resistance
Specification ANSI/UL 969-2018:03 (following)
Test duration 240 h
Rating 125 °C (150 °C) Test passed
Specification ISO 175:2010 (following)
Test duration 168 h
Ethanol (99 %)
[CAS No. 64-17-5] Test passed
Diesel
[CAS No. 68476-34-6] Test passed
IRM 901 Test passed
IRM 902 Test passed
Testing in a condensation changing climate in the presence of sulfur dioxide
Specification DIN 50018:2013-05
Result Test passed
Climate level AHT 1.0 S
Cycles 2
Salt spray test
Specification DIN EN 60068-2-11:2000-02
Result Test passed
Test duration 96 h
High pressure test
Specification IEC 60529:20...

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / KMK HP (60X15) with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.