
INDUSTRIAL COMPONENT DATA

ST 1,5-QUATTRO 3031186 PHOENIX CONTACT Feed-through terminal block

Brand: PHOENIX CONTACT | Manufacturer Part Number: ST 1,5-QUATTRO



Manufacturer	PHOENIX CONTACT
MPN / Reference	ST 1,5-QUATTRO
Catalog number	3031186
Category	Feed-through terminal block
Minimum order	50 Pcs
Document ID	EO-BFB87D95E6
Generated	2026-11-18

Product Overview

Feed-through terminal block
Feed-through terminal, nominal voltage: 500 V, nominal current: 17.5 A, number of connections: 4, connection type: Spring connection, 1st floor, Dimensioning cross-section: 1.5 mm², cross-section: 0.08 mm² - 1.5 mm², installation class: NS 35/7.5, NS 35/15, colour: grey

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	PHOENIX CONTACT > Modular TBs

Additional Product Information

Key Commercial Data
Orderkey 3031186
Packing unit 50 pc
Minimum order quantity 50 pc
Catalog page Page 153 (C-1-2017)
GTIN 4017918186678
Weight per Piece (excluding packing) 7.180 g
Custom tariff number 85369010
Country of origin DE (Germany)
General
Number of levels 1
Number of connections 2

Potentials 1
Nominal cross section 1.5 mm²
Color gray
Insulating material PA
Flammability rating according to UL 94 V0
Area of application Railway industry
Machine building
Plant engineering
Process industry
Rated surge voltage 6 kV
Degree of pollution 3
Overvoltage category III
Insulating material group I
Maximum power dissipation for nominal condition 0.56 W
Maximum load current 17.5 A (in case of a 1.5 mm² conductor cross section, the maximum load current must not be exceeded by the total current of all connected conductors.)
Nominal current IN 17.5 A (with 1.5 mm² conductor cross section)
Nominal voltage UN 500 V
Open side panel Yes
Shock protection test specification DIN EN 50274 (VDE 0660-514):2002-11
Back of the hand protection guaranteed
Finger protection guaranteed
Result of surge voltage test Test passed
Surge voltage test setpoint 7.3 kV
Result of power-frequency withstand voltage test Test passed
Power frequency withstand voltage setpoint 1.89 kV
Result of the test for mechanical stability of terminal points (5 x conductor connection) Test passed
Result of bending test Test passed
Bending test rotation speed 10 rpm
Bending test turns 135
Bending test conductor cross section/...

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / ST 1,5-QUATTRO with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.