INDUSTRIAL COMPONENT DATA

# UDK 4-DUR 249 2775249 PHOENIX CONTACT Component terminal block

**Brand: PHOENIX CONTACT | Manufacturer Part Number: UDK 4-DUR 249**



| | |
|---|---|
| Manufacturer | PHOENIX CONTACT |
| MPN / Reference | UDK 4-DUR 249 |
| Catalog number | 2775249 |
| Category | Component terminal block |
| Minimum order | 50 Pcs |
| Document ID | EO-E1E42ABCC7 |
| Generated | 2026-11-18 |

## Product Overview

Component terminal block
Terminal block for components, nominal voltage: 630 V, nominal current: 32 A, number of connections: 4, connection type: Screw connection, 1st floor, Dimensioning cross-section: 4 mm², cross-section: 0.2 mm² - 6 mm², mounting class: NS 35/7.5, NS 35/15, NS 32, colour: grey

STRUCTURED PRODUCT DATA

## Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

## Classification & Catalog Path

| | |
|---|---|
| Catalog path | PHOENIX CONTACT > Modular TBs |

## Additional Product Information

Key Commercial Data
Orderkey 2775249
Packing unit 50 pc
Catalog page Page 494 (C-1-2017)
GTIN 4017918068530
Weight per Piece (excluding packing) 15.780 g
Custom tariff number 85369010
Country of origin PL (Poland)
General
Number of levels 1
Number of connections 4
Nominal cross section 4 mm²

Color gray
Insulating material PA
Flammability rating according to UL 94 V2
Maximum load current the current is determined by the component used
Rated surge voltage 6 kV
Degree of pollution 3
Overvoltage category III
Insulating material group I
Connection in acc. with standard IEC 60947-7-1
Nominal current IN 32 A (the current is determined by the component used)
Nominal voltage UN 630 V
Open side panel Yes
Shock protection test specification DIN EN 50274 (VDE 0660-514):2002-11
Back of the hand protection guaranteed
Finger protection guaranteed
Result of surge voltage test Test passed
Surge voltage test setpoint 9.8 kV
Result of power-frequency withstand voltage test Test passed
Power frequency withstand voltage setpoint 3 kV
Result of the test for mechanical stability of terminal points (5 x conductor connection) Test passed
Result of bending test Test passed
Bending test conductor cross section/weight 0.2 mm² / 0.2 kg
4 mm² / 0.9 kg
6 mm2/ 1.4 kg
Tensile test result Test passed
Conductor cross section tensile test 0.2 mm²
Tractive force setpoint 10 N
Conductor cross section tensile test 4 mm²
Tractive force setpoint 60 N
Conductor cross section tensile test 6 mm²
Tractive force setpoin...

## REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / UDK 4-DUR 249 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

**GLOBAL OFFICES**

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.