
INDUSTRIAL COMPONENT DATA

# UDK 4-DUR 2775207 PHOENIX CONTACT Feed-through terminal block

**Brand: PHOENIX CONTACT | Manufacturer Part Number: UDK 4-DUR**



| | |
|---|---|
| Manufacturer | PHOENIX CONTACT |
| MPN / Reference | UDK 4-DUR |
| Catalog number | 2775207 |
| Category | Feed-through terminal block |
| Minimum order | 50 Pcs |
| Document ID | EO-E947E32329 |
| Generated | 2026-11-18 |

## Product Overview

Feed-through terminal block
Feed-through terminal block, for mounting self-selecting components, nominal voltage: 630 V, nominal current: 32 A, 1st floor, connection type: Screw connection, Sizing cross-section: 4 mm², cross-section: 0.2 mm² - 6 mm², mounting: NS 35/7.5, NS 35/15, NS 32, color: gray

STRUCTURED PRODUCT DATA

## Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

## Classification & Catalog Path

| | |
|---|---|
| Catalog path | PHOENIX CONTACT > Modular TBs |

## Additional Product Information

Key Commercial Data
Orderkey 2775207
Packing unit 50 pc
Catalog page Page 494 (C-1-2017)
GTIN 4017918068509
Weight per Piece (excluding packing) 14.960 g
Custom tariff number 85369010
Country of origin PL (Poland)
General
Number of levels 1
Number of connections 4
Potentials 1

Nominal cross section 4 mm²
Color gray
Insulating material PA
Flammability rating according to UL 94 V2
Maximum load current the current is determined by the component used
Rated surge voltage 8 kV
Degree of pollution 3
Overvoltage category III
Insulating material group I
Maximum power dissipation for nominal condition 1.02 W
Maximum load current A
Nominal current IN 32 A (the current is determined by the component used)
Nominal voltage UN 630 V
Open side panel Yes
Shock protection test specification DIN EN 50274 (VDE 0660-514):2002-11
Back of the hand protection guaranteed
Finger protection guaranteed
Note regarding shock protection The current is determined by the used component.
Result of surge voltage test Test passed
Result of power-frequency withstand voltage test Test passed
Power frequency withstand voltage setpoint 3 kV
Result of the test for mechanical stability of terminal points (5 x conductor connection) Test passed
Result of bending test Test passed
Bending test conductor cross section/weight 0.2 mm² / 0.2 kg
4 mm² / 0.9 kg
6 mm2/ 1.4 kg
Tensile test result Test passed
Conductor cross section tensile test 0.2 mm²
Tractive force setpoint 10 N
Conductor cross section tensile test 4 mm²
Trac...

## REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / UDK 4-DUR with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

**GLOBAL OFFICES**

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.