INDUSTRIAL COMPONENT DATA

UT 4-TG-P/P 3046168 PHOENIX CONTACT Disconnect terminal block

Brand: PHOENIX CONTACT | Manufacturer Part Number: UT 4-TG-P/P



Manufacturer	PHOENIX CONTACT
MPN / Reference	UT 4-TG-P/P
Catalog number	3046168
Category	(Knife) disconnect terminal block
Minimum order	50 Pcs
Document ID	EO-D23CC56C3F
Generated	2026-11-18

Product Overview

Disconnect terminal block
Interruptible terminal, Current and voltage are determined by the connector used., with threaded sockets for test sockets to house test pins, rated voltage: 500 V, rated current: 20 A, connection type: Screw connection, Sizing section: 4 mm², section: 0.14 mm² - 6 mm², mounting: NS 35/7.5, NS 35/15, color: gray

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	PHOENIX CONTACT > Modular TBs

Additional Product Information

Key Commercial Data
Orderkey 3046168
Packing unit 50 pc
Catalog page Page 233 (C-1-2017)
GTIN 4017918975586
Weight per Piece (excluding packing) 12.440 g
Custom tariff number 85369010
Country of origin DE (Germany)
General
Note Current and voltage are determined by the plug used.
Number of levels 1
Number of connections 2

Potentials 1
Nominal cross section 4 mm²
Color gray
Insulating material PA
Flammability rating according to UL 94 V0
Area of application Railway industry
Machine building
Plant engineering
Rated surge voltage 6 kV
Degree of pollution 3
Overvoltage category III
Insulating material group I
Maximum power dissipation for nominal condition 1.02 W
Maximum load current 20 A (with 6 mm² conductor cross section)
20 A (with 6 mm² conductor cross section)
Nominal current IN 20 A (with 4 mm² conductor cross section)
Nominal voltage UN 500 V
Open side panel No
Shock protection test specification DIN EN 50274 (VDE 0660-514):2002-11
Back of the hand protection guaranteed
Finger protection guaranteed
Result of surge voltage test Test passed
Surge voltage test setpoint 7.3 kV
Result of power-frequency withstand voltage test Test passed
Power frequency withstand voltage setpoint 1.89 kV
Result of the test for mechanical stability of terminal points (5 x conductor connection) Test passed
Result of bending test Test passed
Bending test conductor cross section/weight 0.14 mm² / 0.2 kg
4 mm² / 0.9 kg
6 mm2/ 1.4 kg
Tensile test result Test passed
Conductor cross section tensile t...

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / UT 4-TG-P/P with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.