
INDUSTRIAL COMPONENT DATA

UT 6/1P 3060539 PHOENIX CONTACT Feed-through terminal block

Brand: PHOENIX CONTACT | Manufacturer Part Number: UT 6/1P



Manufacturer	PHOENIX CONTACT
MPN / Reference	UT 6/1P
Catalog number	3060539
Category	Feed-through terminal block
Minimum order	50 Pcs
Document ID	EO-F15A68EE20
Generated	2026-11-18

Product Overview

Feed-through terminal block
Feed-through terminal, nominal voltage: 1000 V, nominal current: 41 A, number of connections: 2, connection type: Screw connection / plug-in connection, Dimensioning cross-section: 6 mm², cross-section: 0.2 mm² - 10 mm², mounting class: NS 35/7.5, NS 35/15, colour: grey

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	PHOENIX CONTACT > Modular TBs

Additional Product Information

Key Commercial Data
Orderkey 3060539
Packing unit 50 pc
Minimum order quantity 50 pc
Catalog page Page 355 (C-1-2017)
GTIN 4046356599535
Weight per Piece (excluding packing) 13.270 g
Custom tariff number 85369010
Country of origin CN (China)
General
Number of levels 1
Number of connections 2

Potentials 1
Nominal cross section 6 mm²
Color gray
Insulating material PA
Flammability rating according to UL 94 V0
Rated surge voltage 8 kV
Degree of pollution 3
Overvoltage category III
Insulating material group I
Maximum power dissipation for nominal condition 1.31 W
Maximum load current 41 A (with 10 mm² conductor cross section)
Nominal current IN 41 A
Nominal voltage UN 1000 V
Open side panel Yes
Insertion/withdrawal cycles mechanical 100
Result of surge voltage test Test passed
Surge voltage test setpoint 9.8 kV
Result of power-frequency withstand voltage test Test passed
Power frequency withstand voltage setpoint 4.26 kV
Result of tight fit on support Test passed
Tight fit on carrier NS 35
Setpoint 5 N
Short circuit stability result Test passed
Conductor cross section short circuit testing 6 mm²
Short-time current 0.72 kA
Result of thermal test Test passed
Proof of thermal characteristics (needle flame) effective duration 30 s
Oscillation, broadband noise test result Test passed
Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03
Test spectrum Service life test category 1, class B, body mounted
Test frequency f1= 5 Hz to f2= 150 Hz
ASD level 1.857...

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / UT 6/1P with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.