INDUSTRIAL COMPONENT DATA

PSBJ-GSK/S-N OG 3032890 PHOENIX CONTACT Female test connector

Brand: PHOENIX CONTACT | Manufacturer Part Number: PSBJ-GSK/S-N OG



Manufacturer	PHOENIX CONTACT
MPN / Reference	PSBJ-GSK/S-N OG
Catalog number	3032890
Category	Test plug for terminal blocks
Minimum order	10 Pcs
Document ID	EO-E09E29BD4E
Generated	2026-11-19

Product Overview

Female test connector
Threaded female, for use on UGSK/S sliding link terminal blocks, with sliding link, colour: orange
Test plug strip, For use in UGSK/S slide-type terminal block, with slide, color: orange

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	PHOENIX CONTACT > Modular TBs

Additional Product Information

Technical dataNotesNote on application For use in UGSK/S slide-type terminal block
Product propertiesProduct type Test socket
Data management status
Article revision 02
Connection dataTest socket torque 0.6
DimensionsWidth 6 mm
Height 4.8 mm
Depth 44 mm
Material specificationsColor orange (RAL 2003)
Contact material PE-LD, silver-plated brass
Environmental and real-life conditionsAmbient conditions
Ambient temperature (operation) -60 °C ... 105 °C (max. short-term operating temperature RTI Elec.)
Ambient temperature (storage/transport) -25 °C ... 60 °C (for a short time, not exceeding 24 h, -60 °C to +70 °C)

Ambient temperature (assembly) -5 °C ... 70 °C
Ambient temperature (actuation) -5 °C ... 70 °C
Permissible humidity (storage/transport) 30 % ... 70 %

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / PSBJ-GSK/S-N OG with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.