
INDUSTRIAL COMPONENT DATA

# UTTB 4-MT 3044775 PHOENIX CONTACT Knife disconnect terminal block

**Brand: PHOENIX CONTACT | Manufacturer Part Number: UTTB 4-MT**



| | |
|---|---|
| Manufacturer | PHOENIX CONTACT |
| MPN / Reference | UTTB 4-MT |
| Catalog number | 3044775 |
| Category | (Knife) disconnect terminal block |
| Minimum order | 50 Pcs |
| Document ID | EO-E6838FE343 |
| Generated | 2026-11-18 |

## Product Overview

Knife disconnect terminal block
Blade interruptible terminal block, nominal voltage: 500 V, nominal current: 30 A, connection type: Screw connection, Sizing cross-section: 4 mm², cross-section: 0.14 mm² - 6 mm², Separation zone, mounting: NS 35/7.5, NS 35/15, color: gray

STRUCTURED PRODUCT DATA

## Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

## Classification & Catalog Path

| | |
|---|---|
| Catalog path | PHOENIX CONTACT > Modular TBs |

## Additional Product Information

Key Commercial Data
Orderkey 3044775
Packing unit 50 pc
Catalog page Page 237 (C-1-2017)
GTIN 4017918997106
Weight per Piece (excluding packing) 20.660 g
Custom tariff number 85369010
Country of origin TR (Turkey)
General
Number of levels 2
Number of connections 4
Potentials 1
Nominal cross section 4 mm²

Color gray
Insulating material PA
Flammability rating according to UL 94 V0
Rated surge voltage 6 kV
Degree of pollution 3
Overvoltage category III
Insulating material group I
Maximum power dissipation for nominal condition 1.02 W (the value is multiplied when connecting multiple levels)
Maximum load current 38 A (with 6 mm² conductor cross section)
Nominal current IN 30 A
Nominal voltage UN 500 V
Maximum load current 20 A (with 6 mm² conductor cross section)
Nominal current IN 20 A
Nominal voltage UN 500 V
Open side panel Yes
Shock protection test specification DIN EN 50274 (VDE 0660-514):2002-11
Back of the hand protection guaranteed
Finger protection guaranteed
Result of surge voltage test Test passed
Surge voltage test setpoint 7.3 kV
Result of power-frequency withstand voltage test Test passed
Power frequency withstand voltage setpoint 1.89 kV
Result of the test for mechanical stability of terminal points (5 x conductor connection) Test passed
Result of bending test Test passed
Bending test rotation speed 10 rpm
Bending test turns 135
Bending test conductor cross section/weight 0.14 mm² / 0.2 kg
4 mm² / 0.9 kg
6 mm2/ 1.4 kg
Tensile test result Test passed
Conductor cros...

## REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / UTTB 4-MT with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

**GLOBAL OFFICES**

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.