
INDUSTRIAL COMPONENT DATA

UC-TM 6 YE 0818331 PHOENIX CONTACT Marker for terminal blocks

Brand: PHOENIX CONTACT | Manufacturer Part Number: UC-TM 6 YE



Manufacturer	PHOENIX CONTACT
MPN / Reference	UC-TM 6 YE
Catalog number	0818331
Category	Labelling for terminal block
Minimum order	10 Pcs
Document ID	EO-5074CAC9B1
Generated	2026-11-18

Product Overview

Marker for terminal blocks
Marker for terminals, Mat, yellow, unlabeled, labelable with: BLUEMARKIDCOLOR, BLUEMARKID, BLUEMARK CLED, PLOTMARK, CMS-P1-PLOTTER, mounting class: interlock, for terminal width: 6.2 mm, useful surface: 5.6 x 10.5 mm, Number of individual indexes: 80

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	PHOENIX CONTACT > MS Material

Additional Product Information

Key Commercial Data
Orderkey 0818331
Packing unit 10 pc
Minimum order quantity 10 pc
Catalog page Page 118 (C-3-2017)
GTIN 4046356135429
Weight per Piece (excluding packing) 11.570 g
Custom tariff number 39269097
Country of origin PL (Poland)
Dimensions
Width (a) 6 mm
Ambient conditions

Ambient temperature (operation) -40 °C ... 120 °C
Recommended storage conditions 23 °C/50 % relative humidity. Storage in a dry and dark place in the original packaging is recommended.
General
Note Can be labeled with CMS
Color yellow
Type high
Components free from silicone and halogen
Flammability rating according to UL 94 V2
Material PA
RoHS compliant Yes
Wipe resistance DIN EN 61010-1 (VDE 0411-1)
Number of individual labels 80
Number of individual labels per row 10
Printability UV LED technology
Device 5147999 BLUEMARK CLED
Test for substances that would hinder coating with paint or varnish VW PV 3.10.7:2005-02
Result Test passed
Test specification weathering-resistance Following ISO 4892-2:2013-03
Test duration 96 h
Wipe resistance test result Test passed
Salt spray test specification DIN EN 60068-2-11:2000-02
Test duration 96 h
Salt spray testing result Test passed
Wipe resistance of test specification inscriptions DIN EN 61010-1 (VDE 0411-1):2011-07
Result Test passed
Marking mounting type snap into tall marker groove
Result Test passed
Oxygen index (DIN EN ISO 4589-2) 28,2%
Class I 3
Class F 2
R22 HL 1 - HL 2
R23 HL 1 - HL 2
R24 HL 1 - HL 2
Standards and Regulations
Wipe resistance DI...

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / UC-TM 6 YE with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.