INDUSTRIAL COMPONENT DATA

US-TM 100 CUS 0829948 PHOENIX CONTACT Marker for terminal blocks

Brand: PHOENIX CONTACT | Manufacturer Part Number: US-TM 100 CUS



Manufacturer	PHOENIX CONTACT
MPN / Reference	US-TM 100 CUS
Catalog number	0829948
Category	Labelling for terminal block
Minimum order	1 Pcs
Document ID	EO-C20D4E224D
Generated	2026-11-18

Product Overview

Marker for terminal blocks
Terminal marker, available: per card, white, labeled according to customer's instructions, mounting class: fit into universal label slot, usable surface: 104 x 9.8 mm, Number of individual indexes: 13

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	PHOENIX CONTACT > CABINET add-on

Additional Product Information

Key Commercial Data
Orderkey 0829948
Packing unit 1 pc
Note Made to Order (non-returnable)
Catalog page Page 90 (C-5-2013)
GTIN 4046356609982
Weight per Piece (excluding packing) 15.280 g
Custom tariff number 49119900
Country of origin DE (Germany)
Dimensions
Length (b) 9.8 mm
Width (a) 104 mm
Height (c) 0.5 mm

Ambient conditions
Ambient temperature (operation) -30 °C ... 80 °C
Recommended storage conditions 10-30 °C / 40-70 % relative humidity. Storage in the original packaging is recommended prior to processing.
General
Color white
Type flat
Components Silicone-free
Flammability rating according to UL 94 V0
Material PVC
PVC
Wipe resistance DIN EN 61010-1 (VDE 0411-1)
Number of individual labels 13
Number of individual labels per row 1
Printability Thermal transfer
Device 5146464 THERMOMARK CARD
Ink ribbon 5146451 THERMOMARK CARD-US-MAG1
0801371 THERMOMARK-RIBBON 110-TC
Test for substances that would hinder coating with paint or varnish VW PV 3.10.7:2005-02
Result Test passed
Test specification weathering-resistance Following ISO 4892-2:2013-03
Test duration 96 h
Wipe resistance test result Test passed
Salt spray test specification DIN EN 60068-2-11:2000-02
Test duration 96 h
Salt spray testing result Test passed
Alternating condensation climate with SO2 test specification following DIN 50018:2013-05
Climate level AHT 1.0 S
Cycles 2
Condensation test result Test passed
Wipe resistance of test specification inscriptions DIN EN 61010-1 (VDE 0411-1):2011-07
Result Test passed....

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / US-TM 100 CUS with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.