INDUSTRIAL COMPONENT DATA

TMT (EX8)R 0803066 PHOENIX CONTACT Marker for terminal blocks

Brand: PHOENIX CONTACT | Manufacturer Part Number: TMT (EX8)R



Manufacturer	PHOENIX CONTACT
MPN / Reference	TMT (EX8)R
Catalog number	0803066
Category	Labelling for terminal block
Minimum order	1 Pcs
Document ID	EO-568A5D18BC
Generated	2026-11-18

Product Overview

Marker for terminal blocks
Marker for terminals, Roll, white, unlabeled, labelable with: THERMOMARK ROLL 2.0, THERMOMARK ROLL, THERMOMARK ROLL X1, THERMOMARK ROLLMASTER 300/600, THERMOMARK X1.2, mounting class: interlock, fit into flat index slot, useful surface: 8 x 50000 mm, Number of individual indexes: 1

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	PHOENIX CONTACT > MS Material

Additional Product Information

Key Commercial Data
Orderkey 0803066
Packing unit 1 pc
Note Made to Order (non-returnable)
Catalog page Page 150 (C-3-2017)
GTIN 4046356935555
Weight per Piece (excluding packing) 382.000 g
Custom tariff number 39269092
Country of origin FR (France)
Dimensions
Length (b) 50 m
Width (a) 8 mm

Ambient conditions
Ambient temperature (operation) -30 °C ... 80 °C
Recommended storage conditions 10-30 °C / 40-70 % relative humidity. Storage in the original packaging is recommended prior to processing.
General
Color white
Type flat
Components Silicone-free
Material PVC
RoHS compliant Yes
Wipe resistance DIN EN 61010-1 (VDE 0411-1)
Number of individual labels 1
Number of individual labels per row 1
Printability Thermal transfer
Device 5146477 THERMOMARK ROLL
Ink ribbon 5145384 THERMOMARK-RIBBON 110
Test for substances that would hinder coating with paint or varnish VW PV 3.10.7:2005-02
Result Test passed
Test specification weathering-resistance Following ISO 4892-2:2013-03
Test duration 96 h
Wipe resistance test result Test passed
Salt spray test specification DIN EN 60068-2-11:2000-02
Test duration 96 h
Salt spray testing result Test passed
Alternating condensation climate with SO2 test specification following DIN 50018:2013-05
Climate level AHT 1.0 S
Cycles 2
Condensation test result Test passed
Wipe resistance of test specification inscriptions DIN EN 61010-1 (VDE 0411-1):2011-07
Result Test passed
Marking mounting type snap into universal marker groove
Standards and Regulations
Wi...

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / TMT (EX8)R with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.