INDUSTRIAL COMPONENT DATA

# UM6M-TM (8X12) 0830939 PHOENIX CONTACT Marker for terminal blocks

**Brand: PHOENIX CONTACT | Manufacturer Part Number: UM6M-TM (8X12)**



| | |
|---|---|
| Manufacturer | PHOENIX CONTACT |
| MPN / Reference | UM6M-TM (8X12) |
| Catalog number | 0830939 |
| Category | Labelling for terminal block |
| Minimum order | 10 Pcs |
| Document ID | EO-5D764EE73E |
| Generated | 2026-11-19 |

## Product Overview

Marker for terminal blocks
Markers for labeling terminals of the company ABB / entrelec, 14 units, unlabeled, labelable with THERMOMARK CARD and BLUEMARK, color: white

STRUCTURED PRODUCT DATA

## Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

## Classification & Catalog Path

| | |
|---|---|
| Catalog path | PHOENIX CONTACT > MS Material |

## Additional Product Information

Key Commercial Data
Orderkey 0830939
Packing unit 10 pc
Minimum order quantity 10 pc
Note Made to Order (non-returnable)
Catalog page Page 181 (C-3-2017)
GTIN 4046356910750
Weight per Piece (excluding packing) 1.990 g
Custom tariff number 39269097
Country of origin PL (Poland)
Dimensions
Length (b) 12 mm
Width (a) 8 mm

Ambient conditions
Ambient temperature (operation) -40 °C ... 120 °C
General
Color white
Type high
Components free from silicone, halogen, and cadmium
Flammability rating according to UL 94 V2
Material PC
RoHS compliant Yes
Wipe resistance DIN EN 61010-1 (VDE 0411-1)
Number of individual labels 14
Number of individual labels per row 7
Number of marker strips 2
Printability Thermal transfer
UV LED technology
Device 5146464 THERMOMARK CARD
5147999 BLUEMARK CLED
Ink ribbon 0801371 THERMOMARK-RIBBON 110-TC
Test for substances that would hinder coating with paint or varnish VW PV 3.10.7:2005-02
Result Test passed
Test specification weathering-resistance Following ISO 4892-2:2013-03
Test duration 96 h
Wipe resistance test result Test passed
Salt spray test specification DIN EN 60068-2-11:2000-02
Test duration 96 h
Salt spray testing result Test passed
Alternating condensation climate with SO2 test specification DIN 50018:2013-05
Climate level AHT 1.0 S
Cycles 2
Condensation test result Test passed
Wipe resistance of test specification inscriptions IEC 61010-1:2010-06
Result Test passed
Marking mounting type clip on
Standards and Regulations
Wipe resistance DIN EN 61...

## REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / UM6M-TM (8X12) with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

**GLOBAL OFFICES**

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.