INDUSTRIAL COMPONENT DATA

# MH-B16-17-MULTI-66-PA-LG 1299341 PHOENIX CONTACT Plates for cable passage, outer diameter of the cable: 12x ..

**Brand: PHOENIX CONTACT | Manufacturer Part Number: MH-B16-17-MULTI-66-PA-LG**



| | |
|---|---|
| Manufacturer | PHOENIX CONTACT |
| MPN / Reference | MH-B16-17-MULTI-66-PA-LG |
| Catalog number | 1299341 |
| Category | Gland plate for small distribution boards/switchgear cabinets |
| Minimum order | 1 Pcs |
| Document ID | EO-8028E7861B |
| Generated | 2026-11-18 |

## Product Overview

Plates for cable passage, outer diameter of the cable: 12x 3 mm ... 7mm, 5x 7mm... 13 mm, material: TPE-SEBS (outer material), color: light gray, length: 127 mm, width: 56 mm, height: 19 mm
Cable feed-through plates
Cable feed-through plates, external cable diameter: 12x 3 mm ... 7 mm, 5x 7 mm ... 13 mm, material: TPE-SEBS (external material), color: light grey, length: 127 mm, width: 56 mm, height: 19 mm

STRUCTURED PRODUCT DATA

## Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

## Classification & Catalog Path

| | |
|---|---|
| Catalog path | PHOENIX CONTACT > Industrial plug-in connectors/interfaces |

## Additional Product Information

Technical dataNotesGeneral incl. mounting screws
Product propertiesProduct type Frame for cable sleeves
Connection dataTightening torque 1.8 Nm
DimensionsDimensional drawing
Width 56 mm
Height 19 mm
Length 127 mm
Material specificationsMaterial TPE-SEBS
Flammability rating according to UL 94 V0
Cable/lineExternal cable diameter () 12x 3 mm ... 7 mm
5x 7 mm ... 13 mm

Environmental and real-life conditionsAmbient conditions
Degree of protection IP66
Ambient temperature (operation) -40 °C ... 90 °C
MountingAssembly instructions M4 mounting screw, torque: 1.8 Nm, SW5 Allen key
The mounting screws included should be used for assembly.
Assembly steps:
1) Fix Multigates with the mounting screws provided (observe torque)
2) Make a hole in the membrane (with a screwdriver) or cut off the tip of the cone
3) Guide the cable through the opening (from the outside). Withdraw the cable approximately 20 mm (to improve strain relief).

## REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / MH-B16-17-MULTI-66-PA-LG with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

**GLOBAL OFFICES**

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.