

INDUSTRIAL COMPONENT DATA

C-ME 4/2 3035759 PHOENIX CONTACT Connecting bridge

Brand: PHOENIX CONTACT | Manufacturer Part Number: C-ME 4/2



Manufacturer	PHOENIX CONTACT
MPN / Reference	C-ME 4/2
Catalog number	3035759
Category	Accessories/spare parts for terminals
Minimum order	10 Pcs
Document ID	EO-F3F45D28ED
Generated	2026-07-29

Product Overview

Connecting bridge

Connection bridge for coupling 2 interruptible terminals for measuring circuits

Connection bridge, for connecting 2 test disconnect terminal blocks

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path **PHOENIX CONTACT > Modular TBs**

Additional Product Information

Technical dataProduct propertiesProduct type Switch module

Number of positions 2

Data management status

Article revision 01

DimensionsWidth 12.2 mm

Height 5.2 mm

Depth 23.8 mm

Material specificationsColor orange (RAL 2003)

Material PA

Flammability rating according to UL 94 V0

Environmental and real-life conditionsAmbient conditions

Ambient temperature (operation) -60 °C ... 85 °C

Ambient temperature (storage/transport) -25 °C ... 55 °C (for a short time, not exceeding 24 h, -60 °C to +70 °C)

Ambient temperature (assembly) -5 °C ... 70 °C

Ambient temperature (actuation) -5 °C ... 70 °C
Permissible humidity (storage/transport) 30 % ... 70 %
ETIM for 3035759 Terminal blocks (EC002848)
Feature Name
Feature Value
Type of accessory/spare part (EF000215)
Other
Accessory (EF013236)
Yes
Spare part (EF013237)
No

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / C-ME 4/2 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.