


INDUSTRIAL COMPONENT DATA

PTU 4 3211855 PHOENIX CONTACT Feed-through terminal block

Brand: PHOENIX CONTACT | Manufacturer Part Number: PTU 4



Manufacturer	PHOENIX CONTACT
MPN / Reference	PTU 4
Catalog number	3211855
Category	Feed-through terminal block
Minimum order	50 Pcs
Document ID	EO-E59E62DE8B
Generated	2026-08-01

Product Overview

Feed-through terminal block

Feed-through terminal, nominal voltage: 800 V, nominal current: 32 A, connection type: Push-in connection, Dimensioning cross-section: 4 mm², cross-section: 0.2 mm² - 6 mm², connection type: Screw connection, Dimensioning cross-section: 4 mm², cross-section: 0.14 mm² - 6 mm², mounting: NS 35/7.5, NS 35/15, colour: grey

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path PHOENIX CONTACT > Modular TBs

Additional Product Information

Key Commercial Data

Orderkey 3211855

Packing unit 50 pc

Minimum order quantity 50 pc

Note Made to Order (non-returnable)

Catalog page Page 100 (C-1-2017)

GTIN 4055626057262

Weight per Piece (excluding packing) 9.400 g

Custom tariff number 85369010

Country of origin CN (China)

General

Number of levels 1

Number of connections 2
Nominal cross section 4 mm²
Color gray
Insulating material PA
Flammability rating according to UL 94 V0
Rated surge voltage 8 kV
Degree of pollution 3
Overvoltage category III
Insulating material group I
Maximum power dissipation for nominal condition 1.02 W
Connection method Push-in connection
Connection in acc. with standard IEC 60947-7-1
Maximum load current 38 A (the maximum load current must not be exceeded by the total current of all connected conductors)
Nominal current IN 32 A
Nominal voltage UN 800 V
Connection method Screw connection
Connection in acc. with standard IEC 60947-7-1
Maximum load current 38 A (with 6 mm² conductor connection)
Nominal current IN 32 A
Nominal voltage UN 800 V
Open side panel Yes
Shock protection test specification DIN EN 50274 (VDE 0660-514):2002-11
Back of the hand protection guaranteed
Finger protection guaranteed
Result of surge voltage test Test passed
Surge voltage test setpoint 9.8 kV
Result of power-frequency withstand voltage test Test passed
Power frequency withstand voltage setpoint 2 kV
Result of the test for mechanical stability of terminal points (5 x conductor connection) Test passed
Result of bending....

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / PTU 4 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.