

INDUSTRIAL COMPONENT DATA

UT 4-TG-P/P 3046168 PHOENIX CONTACT Disconnect terminal block

Brand: PHOENIX CONTACT | Manufacturer Part Number: UT 4-TG-P/P



Manufacturer	PHOENIX CONTACT
MPN / Reference	UT 4-TG-P/P
Catalog number	3046168
Category	(Knife) disconnect terminal block
Minimum order	50 Pcs
Document ID	EO-514ED8A3BA
Generated	2026-08-04

Product Overview

Disconnect terminal block

Interruptible terminal, Current and voltage are determined by the connector used., with threaded sockets for test sockets to house test pins, rated voltage: 500 V, rated current: 20 A, connection type: Screw connection, Sizing section: 4 mm², section: 0.14 mm² - 6 mm², mounting: NS 35/7.5, NS 35/15, color: gray

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path PHOENIX CONTACT > Modular TBs

Additional Product Information

Key Commercial Data

Orderkey 3046168

Packing unit 50 pc

Catalog page Page 233 (C-1-2017)

GTIN 4017918975586

Weight per Piece (excluding packing) 12.440 g

Custom tariff number 85369010

Country of origin DE (Germany)

General

Note Current and voltage are determined by the plug used.

Number of levels 1

Number of connections 2

Potentials 1

Nominal cross section 4 mm²

Color gray

Insulating material PA

Flammability rating according to UL 94 V0

Area of application Railway industry

Machine building

Plant engineering

Rated surge voltage 6 kV

Degree of pollution 3

Overvoltage category III

Insulating material group I

Maximum power dissipation for nominal condition 1.02 W

Maximum load current 20 A (with 6 mm² conductor cross section)

20 A (with 6 mm² conductor cross section)

Nominal current IN 20 A (with 4 mm² conductor cross section)

Nominal voltage UN 500 V

Open side panel No

Shock protection test specification DIN EN 50274 (VDE 0660-514):2002-11

Back of the hand protection guaranteed

Finger protection guaranteed

Result of surge voltage test Test passed

Surge voltage test setpoint 7.3 kV

Result of power-frequency withstand voltage test Test passed

Power frequency withstand voltage setpoint 1.89 kV

Result of the test for mechanical stability of terminal points (5 x conductor connection) Test passed

Result of bending test Test passed

Bending test conductor cross section/weight 0.14 mm² / 0.2 kg

4 mm² / 0.9 kg

6 mm² / 1.4 kg

Tensile test result Test passed

Conductor cross section tensile t...

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / UT 4-TG-P/P with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.