

INDUSTRIAL COMPONENT DATA

FLKM 20/KDS3-MT/FU/LED/DI/MOD5 1133942 PHOENIX CONTACT VARIOFACE 10-channel signal transfer module with blad..

Brand: PHOENIX CONTACT | Manufacturer Part Number: FLKM 20/KDS3-MT/FU/LED/DI/MOD5



Manufacturer	PHOENIX CONTACT
MPN / Reference	FLKM 20/KDS3-MT/FU/LED/DI/MOD5
Catalog number	1133942
Category	Interface module
Minimum order	1 Pcs
Document ID	EO-803462A6D2
Generated	2026-08-06

Product Overview

VARIOFACE 10-channel signal transfer module with blade-interruptible terminal blocks and test sockets for the field and system side, designed for system migration from MOD 5 to ABB S800 I/O

VARIOFACE termination board, for 10 channels, with interruptible blade terminals and female test connectors for field and system side, designed for MOD 5 system migration to ABB S800 I/O

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path **PHOENIX CONTACT > INTERFACE Components (IF)**

Additional Product Information

ETIM for 1133942 PLC's (EC002780)

Feature Name

Feature Value

Type of electrical connection, field-sided (EF005525)

Screw connection

Type of electrical connection, control sided (EF008549)

Blade terminal

Number of poles (EF001391)

20

Rated voltage (EF000228)

30 V
Rated current (EF000227)
0.07 A
Depth (EF000049)
50.4 mm
Width (EF000008)
67.4 mm
Height (EF000040)
77 mm
Mounting method (EF000003)
DIN rail (top hat rail) 35 mm

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / FLKM 20/KDS3-MT/FU/LED/DI/MOD5 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.