

INDUSTRIAL COMPONENT DATA

LPO 10 3270529 PHOENIX CONTACT Branch connector, nominal voltage: 800 V, nominal current: 24 A, number of po..

Brand: PHOENIX CONTACT | Manufacturer Part Number: LPO 10



Manufacturer	PHOENIX CONTACT
MPN / Reference	LPO 10
Catalog number	3270529
Category	Test plug for terminal blocks
Minimum order	20 Pcs
Document ID	EO-5B4CB52753
Generated	2026-08-06

Product Overview

Branch connector, nominal voltage: 800 V, nominal current: 24 A, number of poles: 1, connection type: Push-in connection, Dimensioning cross-section: 2.5 mm², cross-section: 0.14 mm²- 4 mm², colour: grey

Branch connector, rated voltage: 800 V, rated current: 24 A, number of poles: 1, connection type: Push-in connection, Sizing cross-section: 2.5 mm², cross-section: 0.14 mm²- 4 mm², color: gray

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	PHOENIX CONTACT > Modular TBs
--------------	-------------------------------

Additional Product Information

ETIM for 3270529 Terminal blocks (EC002555)

Feature Name

Feature Value

Strip length (EF006824)

8 mm

Rated voltage (EF000228)

800 V

Connectable conductor cross section fine-strand without cable end sleeve (EF007341)

0.14 mm²

Connectable conductor cross section fine-strand with cable end sleeve (EF007339)

0.14 mm²

Connectable conductor cross section solid-core (EF007337)

0.14 mm²

Type of electric connection (EF003961)

Other

Connectable (EF006169)

No

Number of poles (EF001391)

1

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / LPO 10 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.