

INDUSTRIAL COMPONENT DATA

UCT-TM 8 GN CUS 0829622 PHOENIX CONTACT Marker for terminal blocks

Brand: PHOENIX CONTACT | Manufacturer Part Number: UCT-TM 8 GN CUS



Manufacturer	PHOENIX CONTACT
MPN / Reference	UCT-TM 8 GN CUS
Catalog number	0829622
Category	Labelling for terminal block
Minimum order	1 Pcs
Document ID	EO-690C8F98A7
Generated	2026-08-03

Product Overview

Marker for terminal blocks

Terminal marker, available: by mats, green, labeled according to customer's instructions, mounting class: fit in groove for high index, for terminal width: 8.2 mm, usable area: 7.6 x 10.5 mm, Number of individual indices: 42

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path **PHOENIX CONTACT > CABINET add-on**

Additional Product Information

Key Commercial Data

Orderkey 0829622

Packing unit 1 pc

Note Made to Order (non-returnable)

Catalog page Page 84 (C-5-2013)

GTIN 4046356597715

Weight per Piece (excluding packing) 13.800 g

Custom tariff number 49119900

Country of origin DE (Germany)

Dimensions

Length (b) 10.5 mm

Width (a) 7.6 mm

Height (c) 4.76 mm

Ambient conditions

Ambient temperature (operation) -40 °C ... 120 °C

General

Note Can be labeled via thermal transfer

Color green

Type high

Components free from silicone and halogen

Flammability rating according to UL 94 V0

Material PC

PC

RoHS compliant Yes

Wipe resistance DIN EN 61010-1 (VDE 0411-1)

Number of individual labels 42

Number of individual labels per row 7

Printability Thermal transfer

Inkjet printing

Device 5146464 THERMOMARK CARD

5146480 THERMOMARK CARD-UCT-MAG1

5147888 BLUEMARK LED

5147999 BLUEMARK CLED

Ink ribbon 0801371 THERMOMARK-RIBBON 110-TC

5147421 BLUEMARK FLUID-CARTRIDGE

5146662 BLUEMARK CLED-FLUID-CARTR.

Test for substances that would hinder coating with paint or varnish VW PV 3.10.7:2005-02

Result Test passed

Test specification weathering-resistance Following ISO 4892-2:2013-03

Test duration 96 h

Wipe resistance test result Test passed

Salt spray test specification DIN EN 60068-2-11:2000-02

Test duration 96 h

Salt spray testing result Test passed

Alternating condensation climate with SO2 test specification DIN 50018:2013-05

Climate level AHT 1.0 S

Cycles 2

Condensation test result Test passed

Wipe resistance of test specification inscription...

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / UCT-TM 8 GN CUS with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.