

INDUSTRIAL COMPONENT DATA

UM6R-TM (8X10) 0830932 PHOENIX CONTACT Marker for terminal blocks

Brand: PHOENIX CONTACT | Manufacturer Part Number: UM6R-TM (8X10)



Manufacturer	PHOENIX CONTACT
MPN / Reference	UM6R-TM (8X10)
Catalog number	0830932
Category	Labelling for terminal block
Minimum order	10 Pcs
Document ID	EO-0B41901AB8
Generated	2026-08-06

Product Overview

Marker for terminal blocks

Markers for labeling terminals of the company ABB / entrelec, 14 units, unlabeled, labelable with THERMOMARK CARD and BLUEMARK, color: white

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	PHOENIX CONTACT > MS Material
--------------	-------------------------------

Additional Product Information

Key Commercial Data

Orderkey 0830932

Packing unit 10 pc

Minimum order quantity 10 pc

Note Made to Order (non-returnable)

Catalog page Page 182 (C-3-2017)

GTIN 4046356910675

Weight per Piece (excluding packing) 1.750 g

Custom tariff number 39269097

Country of origin PL (Poland)

Dimensions

Length (b) 10 mm

Width (a) 8 mm

Ambient conditions

Ambient temperature (operation) -40 °C ... 120 °C

General

Color white

Type high

Components free from silicone, halogen, and cadmium

Flammability rating according to UL 94 V2

Material PC

RoHS compliant Yes

Wipe resistance DIN EN 61010-1 (VDE 0411-1)

Number of individual labels 14

Number of individual labels per row 7

Number of marker strips 2

Printability Thermal transfer

UV LED technology

Device 5146464 THERMOMARK CARD

5147999 BLUEMARK CLED

Ink ribbon 0801371 THERMOMARK-RIBBON 110-TC

Test for substances that would hinder coating with paint or varnish VW PV 3.10.7:2005-02

Result Test passed

Test specification weathering-resistance Following ISO 4892-2:2013-03

Test duration 96 h

Wipe resistance test result Test passed

Salt spray test specification DIN EN 60068-2-11:2000-02

Test duration 96 h

Salt spray testing result Test passed

Alternating condensation climate with SO2 test specification DIN 50018:2013-05

Climate level AHT 1.0 S

Cycles 2

Condensation test result Test passed

Wipe resistance of test specification inscriptions IEC 61010-1:2010-06

Result Test passed

Marking mounting type clip on

Standards and Regulations

Wipe resistance DIN EN 61...

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / UM6R-TM (8X10) with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.