

INDUSTRIAL COMPONENT DATA

RCK-TGUM/BL16+3/20,0PUR-UX 1260762 PHOENIX CONTACT

Main cable, application: Sensor/actuator box, number of p..

Brand: PHOENIX CONTACT | Manufacturer Part Number: RCK-TGUM/BL16+3/20,0PUR-UX



Manufacturer	PHOENIX CONTACT
MPN / Reference	RCK-TGUM/BL16+3/20,0PUR-UX
Catalog number	1260762
Category	Sensor-actuator patch cord
Minimum order	2 Pcs
Document ID	EO-78CF8E54C6
Generated	2026-08-05

Product Overview

Main cable, application: Sensor/actuator box, number of poles: 19, status indication: no; Main cable connection: M23 connection female, cable length: 20 m, shielding: no, The item does not contain lead according to the RoHS II directive without the exception 6c (Pb< 0.1%)

Cable

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path PHOENIX CONTACT > Field Device Connectors (FDC)

Additional Product Information

ETIM for 1260762 Sensors (EC001855)

Feature Name

Feature Value

Number of poles (EF001391)

19

Cable length (EF000536)

20 m

Material of cable sheath (EF004136)

Other

Halogen free (EF000025)

Yes

Colour cable sheath (EF008249)

Other

With LED indication (EF005950)

No

Screened (EF000881)

No

Cable type (EF000081)

Multi-core

Vulcanize (EF004115)

No

Permitted cable outer temperature after assembling without vibration (EF001686)

-40 °C

Permitted cable outer temperature during assembling/handling (EF001685)

-5 °C

Rated voltage (EF000228)

48 V

Degree of protection (IP) (EF005474)

IP65

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / RCK-TGUM/BL16+3/20,0PUR-UX with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.