

INDUSTRIAL COMPONENT DATA

RSCWE 6-3/4SL 1029994 PHOENIX CONTACT Test terminal strip, nom. voltage: 400 V AC/DC, connection method: Rin..

Brand: PHOENIX CONTACT | Manufacturer Part Number: RSCWE 6-3/4SL



Manufacturer	PHOENIX CONTACT
MPN / Reference	RSCWE 6-3/4SL
Catalog number	1029994
Category	Accessories/spare parts for terminals
Minimum order	1 Pcs
Document ID	EO-67ABF94157
Generated	2026-08-04

Product Overview

Test terminal strip, nom. voltage: 400 V AC/DC, connection method: Ring cable lug, number of connections: 8, number of positions: 4, width: 55.6 mm, height: 80.9 mm, color: gray, mounting type: Insertion in base strip

Test pin strip, rated voltage: 400 V, rated current: 24 A, number of connections: 8, number of poles: 4, connection type: Ring wire terminal, 1st floor, Sizing cross-section: 6 mm², mounting class: Wall mounting, color: gray

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path PHOENIX CONTACT > Enclosures connectivity

Additional Product Information

Key Commercial Data

Orderkey 1029994

Packing unit 1

Catalog page Page 644 (C-1-2019)

GTIN 4055626532622

Custom tariff number 85366990

Drawings

Dimensions

Mounting

Classifications

General

Connection data

Standards and Regulations

Drawings

Circuit diagram

Circuit diagram

Back to topGeneral

Number of positions 4

Number of levels 1

Number of connections 8

Potentials 4

Nominal cross section 6 mm²

Color gray

Insulating material PA

Flammability rating according to UL 94 V0

Rated surge voltage 4 kV

Test surge voltage 5 kV

Overvoltage category III

Insulating material group I

Maximum power dissipation for nominal condition 1.31 W

Maximum load current 30 A (with 10 mm² conductor cross section)

Current I_{th} 24 A

Nominal voltage UN 400 V AC/DC

Open side panel No

Shock protection test specification DIN EN 50274 (VDE 0660-514):2002-11

Back of the hand protection guaranteed

Note regarding shock protection

Result of surge voltage test Test passed

Surge voltage test setpoint 4.8 kV

Result of power-frequency withstand voltage test Test passed

Power frequency withstand voltage setpoint 1.89 kV

Result of tight fit on support Test passed

Setpoint 5 N

Result of thermal test Test passed

Proof of thermal characteristics (needle flame) effective duration 30 s

Oscillation, broadband noise test result Test passed

Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03

Test spectrum Service life test category 2, bogie-mounted

Test frequency f₁= 5 Hz to f₂= 250 Hz

ASD level 6....

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / RSCWE 6-3/4SL with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.