

INDUSTRIAL COMPONENT DATA

SACC-E-M12MSB-5CON-M20/0,5 1147729 PHOENIX CONTACT

Conect. plug. to be apar. Front wall, Male connector, str..

Brand: PHOENIX CONTACT | Manufacturer Part Number: SACC-E-M12MSB-5CON-M20/0,5



Manufacturer	PHOENIX CONTACT
MPN / Reference	SACC-E-M12MSB-5CON-M20/0,5
Catalog number	1147729
Category	Circular connector, mounting (with cable)
Minimum order	50 Pcs
Document ID	EO-4C615CC437
Generated	2026-08-03

Product Overview

Conect. plug. to be apar. Front wall, Male connector, straight, M12, B-coding, to free cable end, Single stranded wires, cable length: 0.5 m, 0.34 mm², TPE braided wire, encapsulated, this item is expected to be lead-free from the fourth quarter of 2025 in accordance with RoHS II without exception 6c (Pb)

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path **PHOENIX CONTACT > Field Device Connectors (FDC)**

Additional Product Information

ETIM for 1147729 Connectors (EC003570)

Feature Name

Feature Value

Cable length (EF000536)

0.5 mm

Type of plug-in contact, outer side (EF005528)

None

Mounting method (EF000003)

Front mounting

Housing material (EF001596)

Other

Material core insulation (EF000061)

Other

Material of contact surface (EF004020)

Other

With shield connection (EF002535)

No

Screw-in thread (EF012303)

M12

Core cross section (EF000018)

0.34 mm²

Min. number of insertion cycles (EF012212)

100

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / SACC-E-M12MSB-5CON-M20/0,5 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.