

INDUSTRIAL COMPONENT DATA

ST 2,5-QUATTRO/4P OG 3061910 PHOENIX CONTACT

Feed-through terminal block

Brand: PHOENIX CONTACT | Manufacturer Part Number: ST 2,5-QUATTRO/4P OG



Manufacturer	PHOENIX CONTACT
MPN / Reference	ST 2,5-QUATTRO/4P OG
Catalog number	3061910
Category	Feed-through terminal block
Minimum order	50 Pcs
Document ID	EO-D47090C5A1
Generated	2026-08-05

Product Overview

Feed-through terminal block

Feed-through, connection type: Spring connection / plug-in connection, number of connections: 4, cross-section: 0.08 mm² - 4 mm², AWG: 28 - 12, width: 5.2 mm, colour: orange, mounting class: NS 35/7.5, NS 35/15

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path PHOENIX CONTACT > Modular TBs

Additional Product Information

Key Commercial Data

Orderkey 3061910

Packing unit 50 pc

Minimum order quantity 50 pc

Note Made to Order (non-returnable)

GTIN 4046356669184

Weight per Piece (excluding packing) 9.590 g

Custom tariff number 85369010

Country of origin PL (Poland)

General

Number of levels 1

Number of connections 4

Nominal cross section 2.5 mm²

Color orange
Insulating material PA
Flammability rating according to UL 94 V0
Rated surge voltage 6 kV
Degree of pollution 3
Overvoltage category III
Insulating material group I
Maximum power dissipation for nominal condition 0.77 W
Connection in acc. with standard IEC 61984
Nominal current IN 24 A
Maximum load current 24 A
Nominal voltage UN 500 V
Open side panel Yes
Insertion/withdrawal cycles mechanical 100
Result of surge voltage test Test passed
Surge voltage test setpoint 7.3 kV
Result of power-frequency withstand voltage test Test passed
Power frequency withstand voltage setpoint 1.89 kV
Result of tight fit on support Test passed
Tight fit on carrier NS 35
Setpoint 1 N
Short circuit stability result Test passed
Conductor cross section short circuit testing 2.5 mm²
Short-time current 0.3 kA
Result of thermal test Test passed
Proof of thermal characteristics (needle flame) effective duration 30 s
Oscillation, broadband noise test result Test passed
Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03
Test spectrum Service life test category 1, class B, body mounted
Test frequency f1= 5 Hz to f2= 150 Hz
ASD level 0.964....

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / ST 2,5-QUATTRO/4P OG with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.