

INDUSTRIAL COMPONENT DATA

ST 2,5-QUATTRO/4P BU 3042081 PHOENIX CONTACT

Feed-through terminal block

Brand: PHOENIX CONTACT | Manufacturer Part Number: ST 2,5-QUATTRO/4P BU



Manufacturer	PHOENIX CONTACT
MPN / Reference	ST 2,5-QUATTRO/4P BU
Catalog number	3042081
Category	Feed-through terminal block
Minimum order	50 Pcs
Document ID	EO-C00C55B7F4
Generated	2026-08-01

Product Overview

Feed-through terminal block

Multi-pole feed-through terminal block with double connection for connector on both sides, width: 5.2 mm, color: blue

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path PHOENIX CONTACT > Modular TBs

Additional Product Information

Key Commercial Data

Orderkey 3042081

Packing unit 50 pc

Minimum order quantity 50 pc

Note Made to Order (non-returnable)

Catalog page Page 289 (C-1-2017)

GTIN 4017918927134

Weight per Piece (excluding packing) 9.510 g

Custom tariff number 85369010

Country of origin PL (Poland)

General

Number of levels 1

Number of connections 4

Nominal cross section 2.5 mm²

Color blue
Insulating material PA
Flammability rating according to UL 94 V0
Area of application Railway industry
Machine building
Plant engineering
Rated surge voltage 6 kV
Degree of pollution 3
Overvoltage category III
Insulating material group I
Maximum power dissipation for nominal condition 0.77 W
Connection in acc. with standard IEC 61984
Nominal current I_N 24 A
Maximum load current 24 A
Nominal voltage U_N 500 V
Open side panel Yes
Insertion/withdrawal cycles mechanical 100
Result of surge voltage test Test passed
Surge voltage test setpoint 7.3 kV
Result of power-frequency withstand voltage test Test passed
Power frequency withstand voltage setpoint 1.89 kV
Result of tight fit on support Test passed
Tight fit on carrier NS 35
Setpoint 1 N
Short circuit stability result Test passed
Conductor cross section short circuit testing 2.5 mm²
Short-time current 0.3 kA
Result of thermal test Test passed
Proof of thermal characteristics (needle flame) effective duration 30 s
Oscillation, broadband noise test result Test passed
Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03
Test spectrum Ser...

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / ST 2,5-QUATTRO/4P BU with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.